

Continued on page below.

Bypassing any switch is intended for testing purposes only. Do not leave switch bypassed during normal operation or the heater's built-in safety mechanisms will be compromised.





Diagnostic Indicator

LED MODE
1 Flash Start up.

2 Flashes Flame. No call for heat. 3 Flashes Ignition lockout.

4 Flashes Valve relay lockout.

