# RE-VERBER-AIR HEATER SUBMITTAL SHEET

# **FA SERIES UNIT HEATERS**

# **GAS-FIRED, INDUCED DRAFT, HOT AIR UNIT HEATERS & ACCESSORIES**

PROJECT ID:	ADDRESS:						
PROJECT NAME:							
DATE:	CITY:	PROV PC:					
Submitted By:	Address:						
Company:							
Phone:	City:						
Email:	Province: Postal Code:						
Engineer:	Contractor:						
Phone/Email:	Phone/Email:						
Address:	Address:						
City:	City:						
Province: Postal Code:		Postal Code:					

	MODEL		INDICATE	BTU/h		APPROX. AVERAGE		VENT LENGTH <sup>1</sup>		TYP. OR RCMD.	CHID
QTY.	MODEL NO.	TAG	INDICATE GAS TYPE	INPUT	OUTPUT	HEAT THROW	AIR TEMP. RISE	MIN.	MAX.	MOUNTING HEIGHTS <sup>1</sup>	SHIP WEIGHT
	FA-100		Nat. or Prop.	100,000	80,000	43 ft.	50°F	3 ft.	40 ft.	12 to 14 ft.	143 lbs.
	FA-125		Nat. or Prop.	125,000	100,000	47 ft.	50°F	3 ft.	40 ft.	14 to 16 ft.	143 lbs.
	FA-150		Nat. or Prop.	150,000	120,00	50 ft.	50°F	3 ft.	40 ft.	14 to 16 ft.	195 lbs.
	FA-175		Nat. or Prop.	175,000	140,000	52 ft.	50°F	3 ft.	40 ft.	15 to 17 ft.	195 lbs.
	FA-200		Nat. or Prop.	200,000	160,000	55 ft.	50°F	3 ft.	40 ft.	15 to 17 ft.	195 lbs.
	FA-225		Nat. or Prop.	225,000	180,000	59 ft.	50°F	3 ft.	40 ft.	16 to 18 ft.	212 lbs.
	FA-250		Nat. or Prop.	250,000	200,000	63 ft.	50°F	3 ft.	40 ft.	16 to 18 ft.	212 lbs.
	FA-300		Nat. or Prop.	300,000	246,000	67 ft.	70°F	3 ft.	40 ft.	18 to 20 ft.	296 lbs.
	FA-400		Nat. or Prop.	400,000	328,000	71 ft.	70°F	3 ft.	40 ft.	20 to 22 ft.	351 lbs.

 $<sup>^{\</sup>rm 1} \mbox{Deduct}$  5 ft. (on 4 in. vent) or 7 ft. (on 6 in. vent) for each elbow added to venting.



# **FA SERIES FEATURED SPECIFICATIONS**

# **APPROVALS**

- ETL Listed
- · Commercial/Industrial Approval
- Indoor Use Only

# **VOLTAGE**

- 120 VAC/60 Hz (primary)
- 24 VAC (thermostatic)
- · Single phase

# MANIFOLD PRESSURE (Inches W.C.)

Natural Gas: 3.5Propane: 10.0

# **INLET PRESSURE (Inches W.C.)**

Natural Gas: 5.0 to 14.0Propane: 11.0 to 14.0

#### **GAS CONNECTION**

FA-100–200: ½" NPT
FA-225–400: ¾" NPT
Field connect to valve

#### **VENT & INLET CONNECTION**

- Category I or III venting
- Rear, horizontal discharge/inlet

## **MOUNTING**

- Non-reversible horizontal mounting
- Mounting with ¾"-16 threaded inserts (qty. 4)

#### **OTHER**

- · Finger-proof fan guards standard
- External indicator lights
- External thermostatic connection
- Approved for 0–2,000 ft. elevations without modifications
- Supplied standard as separated combustion

## LIMITED WARRANTY

- 1 year-Components
- 5 years-Heat exchangers
- 10 years-Burners

MODEL	FLA AMPS	MOTOR TYPE	MOTOR HP	FAN DIAMETER	AXIAL FAN ROTATION	GAS CONNECTION	INLET & VENT CONNECTION
FA-100	5.2	PSC	1/8	18 in.	CCW	1/2" NPT	4" O.D.
FA-125	5.0	PSC	1/6	18 in.	CCW	1/2" NPT	4" O.D.
FA-150	10.7	PSC	1/3	22 in.	CCW	1/2" NPT	6" O.D.
FA-175	10.7	PSC	1/3	22 in.	CCW	1/2" NPT	6" O.D.
FA-200	10.7	PSC	1/3	22 in.	CCW	1/2" NPT	6" O.D.
FA-225	10.7	PSC	1/3	22 in.	CCW	3/4" NPT	6" O.D.
FA-250	10.7	PSC	1/3	22 in.	CCW	3/4" NPT	6" O.D.
FA-300	11.9	PSC	3/4	26 in.	CCW	3/4" NPT	6" O.D.
FA-400	14.3	PSC	1	30 in.	CCW	3/4" NPT	6" O.D.

# **FIELD CONVERSION REFERENCE CHART**

SUPPLIED AS	CONVERSION TO	AVAILABILITY	PART REFERENCE <sup>2</sup>
Separated Combustion	Power Vented, Room Air	Standard	See IOPM
Natural Gas	Propane Gas	Optional	HKP
0-2,000 MSL	2,001–4,500 MSL	Optional	HKN or HKP
0-2,000 MSL	4,501-7,000 MSL	Optional	HKN or HKP
0-2,000 MSL	7,001-9,500 MSL	Optional	HKN or HKP

<sup>&</sup>lt;sup>2</sup>Consult heater Installation, Operation, Parts, and Maintenance Manual for conversion kit reference and instructions.

OPTION	AL ACCESSORIES
CVK-4	4" Concentric Vent Kit for use when venting and combustion air is desired through a single wall or roof penetration. For use with FA-100 and FA-125 models. No vent pipe or B-vent material is included.
CVK-6	6" Concentric Vent Kit for use when venting and combustion air is desired through a single wall or roof penetration. For use with FA-150 through FA-400 models. No vent pipe or B-vent is included.
	BRANT RADIANT HEATERS LIMITED